CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7165-0328:0198 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042

Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999

Email: billw@pottersignal.com

DESIGN: Model PFC-6800 fire alarm control panel. Automatic, Manual, waterflow and sprinkler

supervisory type device and local, auxiliary, releasing, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer to listee's Installation Instruction Manual for

details. System components:

CA-6500: Class A Expander

UD-1000: DACT

3006460, 3006456, 3006467: Main Boards

RA-6075, RA-6075R, RA-6500: Remote Annuciators

3005013, 3005012: EOL Resistors

PSN-1000, PSN-1000(E): Fire Power Expander

SLCE-127: Loop Expander

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fire alarm control units when use with separately listed electrically and functionally

compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual

for details.

02-14-12 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: February 17, 2012 Listing Expires June 30, 2012

Authorized By: JASON DEWITT, Deputy State Fire Marshal

Fire Engineering Division